

CAST IRON FRAME & COVER
(SEE DETAIL GV-SS-040)

FITTING HUB WITH 4" THREADED PLUG.
APPLY TEFLON THREAD TAPE, OR
APPROVED EQUAL, OVER THREADS.

FINISHED GRADE

MINIMUM 4" PVC CLEANOUT (SEE
DETAIL GV-ST-050) PLACED AT
SERVICE PIPE TRANSITION OR 1'
BEYOND PROPERTY LINE,
WHICHEVER IS FARTHER
FROM STREET.

6" X 4"
INCREASER

SERVICE PIPE (6" TYP.)

6" PVC

LINER

SHIELDED COUPLING
OR APPROVED EQUAL

MAIN


EXISTING
SEWER
PIPE

TO HOUSE
→

1.0'

NOTE:
AT EACH TRANSITION WHERE PIPES CHANGE SIZE, THE CONTRACTOR
SHALL USE A MANUFACTURED TRANSITION ADAPTER APPROVED BY
THE MANUFACTURER OR THE ENGINEER.

APPROVED JANUARY 1, 2018



CITY ENGINEER REG 23110

**SANITARY SEWER
SERVICE (CIPP) LINER
(MAIN TO PROPERTY LINE)**

City of
Golden Valley

GV-SS-080