



EXCAVATIONS SHALL BE COMPACTED IN NO GREATER THAN 6" LIFTS.

AN INSPECTION BY THE CITY IS REQUIRED WHEN THE EXCAVATION HAS BEEN FILLED TO THE TOP OF THE CLASS 5 AND BEFORE PLACEMENT OF ASPHALT.

THE CONTRACTOR SHALL PROVIDE A SOIL DENSITY TEST ON THE COMPACTED SOILS FROM A TESTING COMPANY APPROVED BY THE CITY. TEST MUST BE IN COMPLIANCE WITH THE CURRENT MNDOT STANDARD SPECIFICATIONS FOR CONSTRUCTION.

TWO SOIL DENSITY TESTS MUST BE PERFORMED; ONE IN THE UPPER 3' AND ONE BELOW THE UPPER 3'.

APPROVED JANUARY 1, 2018

CITY ENGINEER REG 23110

**TYPE G UTILITY PATCH
IMPROVED STREET 0-5 YRS
MILL AND OVERLAY**

City of
Golden Valley
GV-STRT-130